

Government of Jammu and Kashmir
Office of the Joint Director Fire & Emergency Services
Jammu Range, Jammu

✓ The Principal
Delhi Public School
Udhampur

No: GB/JDJF&ES/Insp. of School/ 3456

Dated: 14-06-2020

Sub: Provisional Fire Safety Certificate.

Ref: Assistant, Fire & Emergency Services Command Udhampur office Letter No. GB/Insp. of School/ADU/593

Dear Sir,

The spot inspection of the above noted school building has been got carried out. The detailed report of which is as under:-

LOCATION / ACCESSIBILITY:

The School is situated at Bye Pass road Udhampur. The School is about 06 kms away from Fire & Emergency Station Udhampur.

DETAIL OF BUILDING:

The School is having three Blocks. Block -"A" is double storied and Block -"B" & "C" are triple storied. There is play ground in the school premises which can be used as Refuge area in case of any mishap.

EXISTING FIRE FIGHTING FACILITIES:

Presently 18 Nos. ABC (DCP) Stored Pressure Type Fire Extinguishers of 06 kg. capacity are installed in the School.

Presently there is one underground water storage tank of 30000 Ltrs. capacity, ten number overhead water storage tanks of different capacities and one bore well are existing in the school building.

(A) FIRST AID FIRE FIGHTING SYSTEM FOR IMPLEMENTATION- ESSENTIAL REQUIREMENT

- i. For both triple storied Blocks Hose Reel Hoses as per B.I.S: specifications should be provided connected with the terrace tank of 5000 Ltrs. capacity. The Hose Reel Hose should be kept at such a place where all floors (i.e. Ground, first and second floor) are covered easily at the time of any emergency. A Fire Pump of desired capacity should be installed near underground water storage tank with dual electric supply for feeding the terrace tank. Two nos. of Yard Hydrants should also provided in the outer periphery of the school for its use in emergency.
- ii. Automatic Fire Detection / Suppression System should be installed in the Physics, Chemistry Bio Laboratories as well as in Library.
- iii. 08 nos. ABC Stored Pressure Type Fire Extinguishers of 04 Kg. capacity each should be provided at appropriate places i.e. Audio / Visual room / Conference room / Big Hall Indoor Games / Kitchen in addition to the already existing fire extinguishers.
- iv. 06 Nos. of Fire buckets filled with fine sand & water should be provided in the school premises as a fire point.
- v. No Hazardous material should be kept inside or outside of the School premises (especially LPG cylinder, Petrol and Diesel etc.)
- vi. Fire Retardant paint should be used for furniture and other wood work.
- vii. All the electric installations should be concealed conduit type. No naked or loose wiring should be allowed in the school premises.
- viii. The management of the school shall be responsible for evacuation of its students, teachers and employees in case of any fire incident.

(B) GENERAL GUIDE LINES/RECOMMENDATIONS

1. Telephone numbers of nearest Fire & Emergency Stations and other allied agencies should be displayed i.e. 101, 01922-270897.
2. Fire fighting system installed in the school building should be checked periodically. Staff and students should be fully trained in handling / operating of fire fighting system installed in the school building.
3. Evacuation drill should be conducted periodically.

The management can proceed ahead for operation subject to fulfillment of Fire/Life Safety General Guidelines / Recommendations mentioned above in letter and spirit forthwith. The validity of this letter will remain enforce for one year from the date of issuance of this letter. The final Fire Safety Certificate of above noted school shall be issued when the recommendations mentioned above are implemented and final inspection of the said school shall be conducted by this Department .

Yours Sincerely


Joint Director,
Fire & Emergency Services
Jammu Range, Jammu