

Office of the Joint Director Fire & Emergency Services  
Jammu Range, Jammu

The Principal  
Delhi Public School  
1/A, Bye Pass Road  
Rathian, Udhampur

Dated: 16.07.2021

No: JDJF&ES/FP/ 3285

Sub: Fire Safety Certificate.


Ref: Your Letter dated:21.06.2021.

Sir,

The inspection of above said school was got carried out by the inspecting officer of this department. During inspection it was found that the management has installed Hose Reel Hoses and First Aid Fire Extinguisher in their school premises. The school is about 08 Km away from Fire and Emergency Station Udhampur and is approachable for fire appliances in case of any emergency. As such, the management can proceed for running the school subject to adopt the following fire safety precautionary measures in letter and spirit:-

1. 01 No. of CO<sub>2</sub> Type fire extinguisher of 02 Kg capacity should be provided near main electric switch board panel in addition to already existing fire extinguishers.
2. All exits/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
3. First Aid Fire fighting system installed in the school building should be checked periodically. Staff and students should be fully trained in handling/operating of fire fighting system installed in the school building. The management shall intimate the office of Assistant Director, Fire & Emergency Services Command Udhampur-Reasi after each quarter that the fire fighting equipments installed in the school are functioning.
4. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
5. The corridor of the building shall not be used for any kind of storage.
6. No Hazardous material should be kept inside of the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, this clearance issued will be treated withdrawn/cancelled.
7. The management of the school shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
8. At present school is having two blocks, one is triple storied and another is four storied. As such no addition/alteration should be made by the school management in the existing structure without prior permission from this department. Any deviation found in this regard, this clearance will be treated withdrawn/cancelled.
9. Telephone numbers of nearest Fire & Emergency Stations should be displayed.
10. The validity of this clearance shall remain in force for one year and same needs to be renewed after checking of fire fighting system installed in the school.

Yours Faithfully

  
Joint Director  
Fire & Emergency Services  
Jammu Range, Jammu  
